



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

Fenster • windows
Rollläden • shutters
Türen + Tore • doors
Fassaden • curtain walling
Baubeschläge • building hardware

TEST CERTIFICATE NO. 16/06-A001-Z2

Version 1.en

PfB-Internal-No. 16/08-A328

Thermal transmittance of frames U_f calculated according to DIN EN ISO 10077-2: 2012-06
“Thermal performance of windows, doors and shutters - Calculation of thermal transmittance -
Part 2: Numerical method for frames (ISO/DIS 10077-2 : 2003) German version EN ISO 10077-2 :
2012”

Applicant

Deceuninck
Ege Profil Tic. ve San.A.Ş.
10003 Sokak No:5 AOSB
35620 Çiğli / İzmir
Turkey

Product type

Inward opening single sash sliding door
with fixed side part, PVC, double glazing

Product Designation

Legend Slide

Dimensions

Frame (w x h) approx. 149 mm. x 65 mm.

Casement (w x h) approx. 76 mm. x 69 mm.

Reinforcement Frame: steel, wall thickness 1,2 mm.

Sash: steel, wall thickness 1,5 mm.

Sealing

TPE

Test Report

Test Report No. 16/06-A001-B2 from July 13, 2016

Results



DIN EN ISO 10077-2 Thermal Transmittance U_f

1,4[W/m²K]

Validity

Period of validity of DIN EN ISO 10077-2: 2012-06

Dipl. Ing. (FH) Rüdiger Müller
Head of Institute



Stephanskirchen
July 13, 2016

Yiğit Altuğ
Responsible Official