



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

PfB ♦ Lackermannweg 24 ♦ D-83071 Stephanskirchen

Fenster • windows
Rollläden • shutters
Türen + Tore • doors
Fassaden • curtain walling
Baubeschläge • building hardware

TEST CERTIFICATE NO. 12/10-A312-Z1

Initial type testing (ITT) of performance characteristics in accordance with EN 14351-1 :2006 + A1 : 2010 “Windows and doors - Product standard, performance characteristics - Part 1: Windows and external pedestrian doorsets without resistance to fire and/or smoke leakage characteristics – German version EN 14351-1:2006 + A1:2010”

Applicant Ege Profil Tic.ve San.A.Ş.
10003 Sokak No:5 AOSB
35620 Çiğli / İzmir

Product type Inward opening tilt and turn single casement window with fixed glazing bottom part, PVC, double glazing


Product name Zendow series single casement window

Dimension Total outside dimensions (W x H) max. 1400 mm x 2300 mm

Sealing TPE

Hardware Deceuninck

Classification according to test report No. 12/10-A312-B1 from October 19, 2012:



EN 1026	Air Permeability	EN 12207	Class 4
EN 1027	Water tightness	EN 12208	Class 9A
EN 12211	Resistance to wind load	EN 12210	Class C2/B3

Validity Period of validity of EN 14351-1 : 2006 + A1 : 2010

Dipl. Ing. Matthias Demmel
Head of Notified Test Body

PfB GmbH & Co. Prüfzentrum für Bauelemente KG
AG Traunstein HRA 8871
Lackermannweg 24, 83071 Stephanskirchen
phG PfB Verwaltungs GmbH
Geschäftsführer: Matthias Demmel, Rüdiger Müller
AG Traunstein HRB 16490



Stephanskirchen,
October 19, 2012

Telefon +49 (0) 80 36 / 67 49 47 0
Telefax +49 (0) 80 36 / 67 49 47 28
www.pfb-rosenheim.de
info@pfb-rosenheim.de

Dipl.-Ing. (FH) Christoph Geiger
Responsible Official

Sparkasse Rosenheim
Bankleitzahl 711 500 00
Kontonummer 500 556 741
Steuer-Nr.156/172/13009
USt-IdNr. DE245353602



Anerkannte Prüfstelle
Landesbauordnung
BAY 33
Notified Body
No. 1644