



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

PfB ♦ Lackermannweg 24 ♦ D-83071 Stephanskirchen

Fenster • windows
Rollläden • shutters
Türen + Tore • doors
Fassaden • curtain walling
Baubeschläge • building hardware

TEST CERTIFICATE NO. 12/10-A312-Z3

Initial type testing (ITT) of performance characteristics in accordance with EN 14351-1 :2006 + A1 : 2010 “Windows and doors - Product standard, performance characteristics - Part 1: Windows and external pedestrian doorsets without resistance to fire and/or smoke leakage characteristics – German version EN 14351-1:2006 + A1:2010”

Applicant Ege Profil Tic.ve San.A.Ş.
10003 Sokak No:5 AOSB
35620 Çiğli / İzmir

Product type Inward opening single casement door,
PVC, double glazing

Product name Zendow series door

Dimension Total outside dimensions (W x H)

max. 900 mm x 2200 mm

Sealing TPE

Hardware Deceuninck

Classification according to test report No. 12/10-A312-B3 from October 19, 2012:



EN 1026 Air Permeability EN 12207 Class 4

EN 1027 Water tightness EN 12208 Class 9A

EN 12211 Resistance to wind load EN 12210 Class C5/B5

Validity Period of validity of EN 14351-1 : 2006 + A1 : 2010

Dipl. Ing. Matthias Demmel
Head of Notified Test Body

PfB GmbH & Co. Prüfzentrum für Bauelemente KG
AG Traunstein HRA 8871
Lackermannweg 24, 83071 Stephanskirchen
phG PfB Verwaltungs GmbH
Geschäftsführer: Matthias Demmel, Rüdiger Müller
AG Traunstein HRB 16490



Stephanskirchen,
October 19, 2012

Telefon +49 (0) 80 36 / 67 49 47 0
Telefax +49 (0) 80 36 / 67 49 47 28
www.pfb-rosenheim.de
info@pfb-rosenheim.de

Dipl.-Ing. (FH) Christoph Geiger
Responsible Official

Sparkasse Rosenheim
Bankleitzahl 711 500 00
Kontonummer 500 556 741
Steuer-Nr.156/172/13009
USt-IdNr. DE245353602



Anerkannte Prüfstelle
Landesbauordnung
BAY 33

Notified Body
No. 1644