



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

PfB ♦ Lackermannweg 24 ♦ D-83071 Stephanskirchen

Fenster • windows
Rollläden • shutters
Türen + Tore • doors
Fassaden • curtain walling
Baubeschlüsse • building hardware

TEST CERTIFICATE NO. 12/10-A312-Z2

Initial type testing (ITT) of performance characteristics in accordance with EN 14351-1 :2006 + A1 : 2010 "Windows and doors - Product standard, performance characteristics - Part 1: Windows and external pedestrian doorsets without resistance to fire and/or smoke leakage characteristics – German version EN 14351-1:2006 + A1:2010"

Applicant Ege Profil Tic.ve San.A.Ş.
10003 Sokak No:5 AOSB
35620 Çiğli / İzmir

Product type Inward opening one turn, one tilt and turn doors,
PVC, double glazing


Product name Zendow series two casement door

Dimension Total outside dimensions (W x H) max. 1200 mm x 2100 mm

Sealing TPE

Hardware Deceuninck

Classification according to test report No. 12/10-A312-B2 from October 19, 2012:



EN 1026	Air Permeability	EN 12207	Class 4
EN 1027	Water tightness	EN 12208	Class 9A
EN 12211	Resistance to wind load	EN 12210	Class C2/B3

Validity Period of validity of EN 14351-1 : 2006 + A1 : 2010

Dipl. Ing. Matthias Demmel
Head of Notified Test Body

PfB GmbH & Co. Prüfzentrum für Bauelemente KG
AG Traunstein HRA 8871
Lackermannweg 24, 83071 Stephanskirchen
phG PfB Verwaltungs GmbH
Geschäftsführer: Matthias Demmel, Rüdiger Müller
AG Traunstein HRB 16490



Stephanskirchen,
October 19, 2012

Telefon +49 (0) 80 36 / 67 49 47 0
Telefax +49 (0) 80 36 / 67 49 47 28
www.pfb-rosenheim.de
info@pfb-rosenheim.de

Dipl.-Ing. (FH) Christoph Geiger
Responsible Official

Sparkasse Rosenheim
Bankleitzahl 711 500 00
Kontonummer 500 556 741
Steuer-Nr.156/172/13009
USt-IdNr. DE245353602



Anerkannte Prüfstelle
Landesbauordnung
BAY 33
Notified Body
No. 1644